



Ussery-Rule Architects, P.C.

1804-A Frederica Road
Saint Simons Island, Georgia 31522

PH: 912.638.6688
www.URarch.com

September 4, 2024

Mr. Will Carter


Via Email: will.carter@nickelridgecapital.com

Mr. Carter:

The construction plans prepared by Ussery-Rule Architects for all buildings in the 50 Oaks project specify 6x6, 10/10 WWM welded wire mesh for concrete slab reinforcement. The specification appears on the foundation plan for all buildings within the development. “FRC FIB-300 Micro Fibrillated Synthetic Fiber” generically called “fiber mesh” is a suitable substitute for all concrete slab areas on the plans calling for WWM welded wire mesh. This product should be used per the manufacturer’s guidelines.

Please contact me if you have any questions.

Sincerely,

A handwritten signature in blue ink, appearing to read 'R. Ussery', written over a horizontal line.

Robert C Ussery
Architect – GA: RA003277



RCU : smg